N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14112-48-2835
State Number
23293

EQUIPMENT INSPECTED

State Number: **23293**
Capacity: 2100
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 09/12/2005
Complied: 09/12/2005

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
COMMUNITY ASSOCIATION MGMT.
P.O. BOX 8126
OCEAN ISLE, NC, 28469

OCCUPANT
VILLAS ON OSPREY RIDGE
178 CLUB HOUSE RD
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
04/22/2014	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.27.3.1 Put the Phase I fire service feature in proper working order. [NO RECALL LIGHT AT KEY SWITCH].

2.27.3.3 Put the Phase II fire service feature in proper working order. [DOOR OPEN BUTTON INOPERTIVE AT FIREMANS OPER. PANEL].

Items must be corrected by: 05/22/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
COMMUNITY ASSOCIATION MGMT.
P.O. BOX 8126
OCEAN ISLE, NC, 28469