



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14112-48-3275
State Number
23519

EQUIPMENT INSPECTED

State Number: 23519	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 02/22/2006	Rope Size: 0
Volts: 208	Complied: 02/22/2006	Entrances: 1

OWNER
COMMUNITY ASSOCIATION MGMT.
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469

OCCUPANT
VILLAS ON OSPREY RIDGE
172 CLUB HOUSE RD
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date 04/22/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 05/22/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMMUNITY ASSOCIATION MGMT.
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469