



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14133-17-0522
State Number
23443

EQUIPMENT INSPECTED

State Number: 23443	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 12/07/2005	Rope Size:
Volts: 208	Complied: 01/05/2006	Entrances: 1
OWNER	OCCUPANT	
ALLERGY PARTNERS	1985 HENDESONVILLE RD. LOT 4	
14 MCDOWELL STREET	1985 HENDERSONVILLE RD	
ASHEVILLE, NC, 28801-4104	ASHEVILLE, NC, 28803	

INSPECTION INFORMATION

Inspection Date 05/13/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
8.11	Perform the 5 year full load test.

Items must be corrected by: 06/12/2014

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: asheville elev. 828-274-3633

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALLERGY PARTNERS
14 MCDOWELL STREET
ASHEVILLE, NC, 28801-4104