



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14142-17-1391
State Number
2324

EQUIPMENT INSPECTED

State Number: 2324	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 3000	Manuf: ACE	Speed: 50
Landings: 2	Installed: 05/10/1954	Rope Size:
Volts: 550	Complied: 05/10/1954	Entrances: 2
OWNER	OCCUPANT	
ASC BUSINESS PARK LLC	BLUE RIDGE BUSINESS CENTER	
128 BINGHAM RD	128 BINGHAM RD	
ASHEVILLE, NC, 28806	ASHEVILLE, NC, 28806	

INSPECTION INFORMATION

Inspection Date 05/22/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

note	no violations
note	monitor jack and valve leaks repair as necessary.

Items must be corrected by: 05/22/2014

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Josh Clark

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASC BUSINESS PARK LLC
128 BINGHAM RD
ASHEVILLE, NC, 28806