



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14142-59-2045**  
State Number  
**10537**

EQUIPMENT INSPECTED

State Number: <b>10537</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: GENERAL	Speed: 100
Landings: 2	Installed: 06/15/1983	Rope Size:
Volts: 208	Complied: 07/05/1983	Entrances: 1
OWNER	OCCUPANT	
ASHEVILLE CITY SCHOOLS	LUCY HERRING ADMIN BLDG	
PO BOX 7347	85 MOUNTAIN STREET	
ASHEVILLE, NC, 28802	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 05/22/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 59 - Cannon	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

VIOLATIONS

8.1.1[c] Keys shall be kept on the premises in a location readily accessible to the personnel in the assigned group, but not where they are accessible to the general public. Someone onsite should have a key to the equipment room.

Items must be corrected by: 06/21/2014

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: dwayne taylor

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE CITY SCHOOLS  
PO BOX 7347  
ASHEVILLE, NC, 28802