N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14148-17-4562
State Number
4309

EQUIPMENT INSPECTED

State Number: **4309**
Capacity: 3000
Landings: 4
Volts: 240

Type of Unit: Passenger
Manuf: OTIS
Installed: 02/19/1960
Complied: 02/19/1960

Floor to Floor: B to 3
Speed: 300
Rope Size: 5/8
Entrances: 1

OWNER
ASHEVILLE BUNCOMBE TECH COLL
340 VICTORIA RD
ASHEVILLE, NC, 28801

OCCUPANT
ASHEVILLE BUNCOMBE TECH COMM COLLEGE
1459 SANDHILL RD.
CHANDLER, NC, 28715

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
05/28/2014	Routine	Re-issued	17 - White	BUNCOMBE	11 A

VIOLATIONS

8.6.1.6.5	Provide a class ABC fire extinguisher in machinery space. Expired unit.
8.6.4	Remove old lighting fixture from inside the car.
2.29	Emergency number the elevator car, car top, main floor, and machine room controller and disconnects.
ncbc	Label elevator machine room properly.
8.6.4	Provide anti-rotation cables for both the car and counterweight ropes.

Items must be corrected by: 06/27/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Eddie 828-254-1921 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ASHEVILLE BUNCOMBE TECH COLL
340 VICTORIA RD
ASHEVILLE, NC, 28801