



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14148-17-5111**  
State Number  
**6775**

EQUIPMENT INSPECTED

State Number: <b>6775</b>	Type of Unit: Passenger	Floor to Floor: G to 7
Capacity: 2500	Manuf: WESTINGHOUSE	Speed: 350
Landings: 8	Installed: 11/24/1970	Rope Size: 1/2
Volts: 550	Complied: 02/02/1971	Entrances: 1

OWNER

ASHEVILLE BUNCOMBE TECH COLL  
340 VICOTRIA RD  
ASHEVILLE, NC, 28801

OCCUPANT

ASHEVILLE BUNCOMBE COLL  
1459 SANDHILL RD.  
CANDLER, NC, 28715

INSPECTION INFORMATION

Inspection Date 05/28/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.1.6.5	Provide a class ABC fire extinguisher in machinery space. Out of date.
8.6.4	final notice remove blocks in relay contacts on relays VI G39 AND WTT.
ncbc	Provide in case of fire signs on all elevator lobbies.
ncbc	Provide proper elevator machine room sign
8.6.4	Keep elevator car clutch from hitting 2nd floor door interlock cam.
note	Monitor runby not to exceed 35 inches.
2.29	Emergency number the elevator with all other elevators on campus.

Items must be corrected by: 06/27/2014

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Eddie 828-254-1921

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH COLL  
340 VICOTRIA RD  
ASHEVILLE, NC, 28801