



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14150-59-5523
State Number
11371

EQUIPMENT INSPECTED

State Number: 11371	Type of Unit: Passenger	Floor to Floor: B to 4
Capacity: 2500	Manuf: ASHEVILLE	Speed: 135
Landings: 5	Installed: 12/22/1986	Rope Size:
Volts: 208	Complied: 01/05/2007	Entrances: 1

OWNER

11 NORTH MARKET ST. BLDG.
11 N. MARKET STREET
ASHEVILLE, NC, 28801

OCCUPANT

11 NORTH MARKET ST. BLDG.
11 N. MARKET STREET
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 05/30/2014	Type Inspection Alteration	Certificate Status Issued	Inspector 59 - Cannon	County BUNCOMBE	11 B
-------------------------------	-------------------------------	------------------------------	--------------------------	--------------------	------

VIOLATIONS

note no violations

Items must be corrected by: 05/30/2014

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jerry Southern

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

11 NORTH MARKET ST. BLDG.
11 N. MARKET STREET
ASHEVILLE, NC, 28801