



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14155-48-0879
State Number
13648

EQUIPMENT INSPECTED

State Number: 13648	Type of Unit: Passenger	Floor to Floor: G to -
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 4	Installed: 02/27/1990	Rope Size:
Volts: 208	Complied: 06/01/1990	Entrances: 1
OWNER	OCCUPANT	
INLET WACCHE HOA INC	INLET WACCHE ASSO	
PO BOX 6046	1916 GOOSE CREEK RD SW	
SOUTH BRUNSWICK, NC, 28470	OCEAN ISLE BEACH, NC, 28469	

INSPECTION INFORMATION

Inspection Date 06/04/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.7.5.1	Put the machine room lights in working order.
8.6.1.6.5	Provide a class ABC fire extinguisher in machinery space.

Items must be corrected by: 07/04/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mr Gorman

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

INLET WACCHE HOA INC
PO BOX 6046
SOUTH BRUNSWICK, NC, 28470