



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14156-48-1243
State Number
19289

EQUIPMENT INSPECTED

State Number: 19289	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 04/26/2000	Rope Size:
Volts: 460	Complied: 05/02/2000	Entrances: 1

OWNER

BRUNSWICK COUNTY OPERATIONS SERVICES
P.O. BOX 249
BOLIVIA, NC, 28422

OCCUPANT

SOUTHEASTERN MENTAL HEALTH
45 COURTHOUSE DR.
BOLIVIA, NC, 28422

INSPECTION INFORMATION

Inspection Date 06/05/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Billy

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK COUNTY OPERATIONS SERVICES
P.O. BOX 249
BOLIVIA, NC, 28422