N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14162-52-2661
State Number
20202

EQUIPMENT INSPECTED

State Number: **20202**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 04/18/2002
Complied:

Floor to Floor: 1 to 2
Speed: 95
Rope Size: 0
Entrances: 1

OWNER
BEACH MOUNTAIN CLUB
114 CLUB HOUSE ROAD
BEACH MOUNTAIN, NC, 28604

OCCUPANT
BEACH MOUNTAIN CLUB
114 CLUB HOUSE ROAD
BEACH MOUNTAIN, NC, 28604

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/11/2014	Routine	Re-issued	52 - Sosebee	AVERY

6

VIOLATIONS

8.6.4.7.4 Remove the oil from the pit floor and oil dry. (Pit can tube came out of pit can and oil ran on pit floor.)

8.6 Keep area in front of machine room door clear of all articles.

Items must be corrected by: 07/11/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Beach Mountain Club 828-387-4747 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BEACH MOUNTAIN CLUB
114 CLUB HOUSE ROAD
BEACH MOUNTAIN, NC, 28604