



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14163-36-2726
State Number
19587

EQUIPMENT INSPECTED

State Number: 19587	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 01/22/2001	Rope Size:
Volts: 208	Complied: 01/31/2001	Entrances: 1
OWNER	OCCUPANT	
COMMUNITY ONE	COMMUNITY ONE	
1128 S MAIN ST	1128 S MAIN ST	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 06/12/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

- 8.6.4.13.1[1] Properly maintain door restrictor. (NOT WORKING)
- 2.14.4.2.1 Put the car door gate switch in proper working order.
- 2.27.1.1.2 Put the in car emergency telephone in proper working order.(HANDS FREE PHONE HANGS UP IN THE MIDDLE OF CONVERSATION)

Items must be corrected by: 07/12/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Judy Poe 336-226-1223

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMMUNITY ONE
1128 S MAIN ST
GRAHAM, NC, 27253