



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14163-36-3055
State Number
15559

EQUIPMENT INSPECTED

State Number: 15559	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 05/04/1995	Rope Size:
Volts: 480	Complied: 05/04/1995	Entrances: 1
OWNER	OCCUPANT	
GRAHAM LIBRARY & POLICE BLDG	GRAHAM LIBRARY & POLICE BLDG	
201 S MAIN STREET	201 S MAIN STREET	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 06/12/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ORLANDO RONE 336-570-6711

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GRAHAM LIBRARY & POLICE BLDG
201 S MAIN STREET
GRAHAM, NC, 27253