



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14163-48-4852
State Number
20957

EQUIPMENT INSPECTED

State Number: 20957	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3000	Manuf: THYSSEN KRUPP	Speed: 115
Landings: 2	Installed: 01/29/2003	Rope Size: 0
Volts: 208	Complied: 01/29/2003	Entrances: 1
OWNER	OCCUPANT	
NC COASTAL DEVELOPMENT	ISLANDER RESORT [RESTAURANT]	
1 BECKY STREET	417 W. 2ND. ST.	
OCEAN ISLE, NC, 28461	OCEAN ISLE, NC, 28461	

INSPECTION INFORMATION

Inspection Date 06/12/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.11.2.2.2	Perform the annual no load safety test

Items must be corrected by: 07/12/2014

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: PAUL

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

NC COASTAL DEVELOPMENT
1 BECKY STREET
OCEAN ISLE, NC, 28461