



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14168-48-2062**  
State Number  
**22375**

EQUIPMENT INSPECTED

State Number: <b>22375</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/24/2004	Rope Size: .
Volts: 208	Complied: 06/24/2004	Entrances: 1
OWNER	OCCUPANT	
TONIA GOUDARZI	SOUTHPORT COMMONS BLDG 1	
TG MANAGEMENT	1456 N HOWE ST	
WILMINGTON, NC, 28403	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 06/17/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.3.1	Put the Phase I fire service feature in proper working order. [NO FIRE HAT AT KEY SW.].
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 07/17/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TONIA GOUDARZI  
TG MANAGEMENT  
WILMINGTON, NC, 28403