N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14181-36-1346
State Number
17516

EQUIPMENT INSPECTED

State Number: **17516**
Capacity: 2500
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 07/21/1998
Complied: 07/21/1998

Floor to Floor: B to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
B D DIAGNOSTICS
780 PLANTATION DR
BURLINGTON, NC, 27215

OCCUPANT
B D DIAGNOSTICS
780 PLANTATION DR
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/30/2014	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: DEVIE INGOLD 336-222-9707 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
B D DIAGNOSTICS
780 PLANTATION DR
BURLINGTON, NC, 27215