



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14196-48-5625
State Number
24906

EQUIPMENT INSPECTED

State Number: 24906	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 6	Installed: 06/25/2007	Rope Size:
Volts: 208	Complied:	Entrances: 1

OWNER

SEASIDELANDING PARTNERS LLC
7265 SEASHELL LANE
OCEAN ISLE BEACH, NC, 28469

OCCUPANT

SEASIDE LANDING CONDOS
7265 SEASHELL LANE
OCEAN ISLE BEACH, NC, 28469

INSPECTION INFORMATION

Inspection Date 07/15/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.13.5.1 Put the car door reopening devices in proper working order. [BROKEN DR. OPEN BUTTON].

Items must be corrected by: 08/14/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEASIDELANDING PARTNERS LLC
7265 SEASHELL LANE
OCEAN ISLE BEACH, NC, 28469