N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14198-48-054
State Number
23067

EQUIPMENT INSPECTED

State Number: **23067**
Capacity: 3500
Landings: 4
Volts: 240

Type of Unit: Passenger
Manuf: OTIS
Installed: 09/09/2005
Complied: 09/13/2005

Floor to Floor: 1 to 4
Speed: 100
Rope Size:
Entrances: 2

OWNER
WATERWAY LANDING HOMEOWNERS ASS.
1135 PARK ROAD
SUNSET BEACH, NC, 28468

OCCUPANT
WATERWAY LANDING CONDOS
1135 PARK RD
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/17/2014	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Darlene Jenkins

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
WATERWAY LANDING HOMEOWNERS ASS.
1135 PARK ROAD
SUNSET BEACH, NC, 28468