



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14198-48-4946**  
State Number  
**23065**

EQUIPMENT INSPECTED

|                                  |                         |                        |
|----------------------------------|-------------------------|------------------------|
| State Number: <b>23065</b>       | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 3500                   | Manuf: OTIS             | Speed: 100             |
| Landings: 3                      | Installed: 06/22/2005   | Rope Size: .           |
| Volts: 240                       | Complied: 06/22/2005    | Entrances: 2           |
| OWNER                            | OCCUPANT                |                        |
| WATERWAY LANDING HOMEOWNERS ASS. | WATERWAY LANDING CONDOS |                        |
| 1135 PARK RD                     | 1135 PARK RD            |                        |
| SUNSET BEACH, NC, 28468          | SUNSET BEACH, NC, 28468 |                        |

INSPECTION INFORMATION

|                               |                            |                                 |                          |                     |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date<br>07/17/2014 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>48 - Martin | County<br>BRUNSWICK |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

10

VIOLATIONS

- 2.27.3.1 Put the Phase I fire service feature in proper working order. {LIGHT OUT AT KEY SW.}.
- 2.2.5.1 Put the pit lights in proper working order.

Items must be corrected by: 08/16/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Darlene Jenkins

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WATERWAY LANDING HOMEOWNERS ASS.  
1135 PARK RD  
SUNSET BEACH, NC, 28468