



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14202-36-368**  
State Number  
**24435**

EQUIPMENT INSPECTED

State Number: <b>24435</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 12/19/2006	Rope Size:
Volts: 480	Complied: 12/19/2006	Entrances: 1
OWNER	OCCUPANT	
V.J.C.M.B	ALAMANCE EAR, NOSE & THROAT	
1248 HUFFINE MILL ROAD	1248 HUFFMAN MILL RD	
BURLINGTON, NC, 27515	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 07/21/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SHEILA BEEKER 336-395-1303

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

V.J.C.M.B  
1248 HUFFINE MILL ROAD  
BURLINGTON, NC, 27515