



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14203-48-3094
State Number
19671

EQUIPMENT INSPECTED

State Number: 19671	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 12/07/2000	Rope Size:
Volts: 208	Complied: 12/07/2000	Entrances: 1

OWNER

SEA TRAIL CORPORATION
279 CLUBHOUSE RD
SUNSET BEACH, NC, 28468

OCCUPANT

SEA TRAIL - CAHMPION #35
137 AVIAN DR
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date 07/22/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 08/21/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEA TRAIL CORPORATION
279 CLUBHOUSE RD
SUNSET BEACH, NC, 28468