



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14211-7-1055
State Number
24155

EQUIPMENT INSPECTED

State Number: 24155	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 110
Landings: 2	Installed: 10/30/2006	Rope Size: 0
Volts: 208	Complied: 10/30/2006	Entrances: 1
OWNER	OCCUPANT	
ALLEGHENY COUNTY	ALLEGHENYCOUNTY COURT HOUSE	
348 S MAIN STREET	12 N MAIN STREET	
SPARTA, NC, 29063	SPARTA, NC, 29063	

INSPECTION INFORMATION

Inspection Date 07/30/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ALLEGHANY
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

3

VIOLATIONS

NONE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: KAREN EVANS 336-372-4179

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALLEGHENY COUNTY
348 S MAIN STREET
SPARTA, NC, 29063