N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14211-7-3345
State Number
11204

EQUIPMENT INSPECTED

State Number: **11204**
Capacity: 2100
Landings: 3
Volts: 220

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 07/25/1985
Complied: 07/25/1985

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
THE GREYSTONE INN
2663 ROARING GAP DR.
ROARING GAP NC, NC, 28668

OCCUPANT
THE GREYSTONE INN
2663 ROARING GAP DR.
ROARING GAP NC, NC, 28668

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/30/2014	Routine	Re-issued	7 - Hoffman	ALLEGHANY

3

VIOLATIONS

NONE AT THIS TIME

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: GREYSTONE INN 336-363-5001 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
THE GREYSTONE INN
2663 ROARING GAP DR.
ROARING GAP NC, NC, 28668