N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14212-7-3833
State Number
15672

EQUIPMENT INSPECTED

State Number: **15672**
Capacity: 2000
Landings: 2
Volts: 480

Type of Unit: Passenger
Manuf: KONE
Installed: 09/26/1994
Complied: 09/28/1994

Floor to Floor: 1 to 2
Speed: 80
Rope Size:
Entrances: 1

OWNER
BOTTOMLEYS EVERGREEN FARM
5071 GLADE VALLEY RD.
ENNICE, NC, 28623

OCCUPANT
BOTTOMLEYS EVERGREEN FARM
114 INDUSTRIAL PARK DR.
SPARTA, NC, 28675

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/31/2014	Routine	Re-issued	7 - Hoffman	ALLEGHANY

3

VIOLATIONS

8.11.3.2.1 PERFORM THE ANNUAL RELIEF VALVE TEST

Items must be corrected by: 08/30/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: BLAN BOTTOMLEY 336-657-1705 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BOTTOMLEYS EVERGREEN FARM
5071 GLADE VALLEY RD.
ENNICE, NC, 28623