N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14217-8-1150
State Number
21243

EQUIPMENT INSPECTED

State Number: **21243**	Type of Unit: Passenger	Floor to Floor: 2 to .1
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 1	Installed: 09/04/2003	Rope Size: 0
Volts: 480	Complied: 09/04/2003	Entrances: 1

OWNER
LANESBORO CORRECTIONAL INSTITUTION
P.O.BOX 280
POLKTON, NC, 28135

OCCUPANT
LANESBORO CORRECTIONAL INSTITUTION
552 PRISON CAMP RD
POLKTON, NC, 28135

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
08/05/2014	Routine	Re-issued	8 - Burris	ANSON

4

VIOLATIONS

8.6.4.13 MAKE BOTTOM FLOOR HOISTWAY DOOR SELF CLOSING.

Items must be corrected by: 09/04/2014 Elevator Name: UNION BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: BILL HART 704.695.1013 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
LANESBORO CORRECTIONAL INSTITUTION
P.O.BOX 280
POLKTON, NC, 28135