

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-807-2770

| |
|--|
| Report Number 14217-8-4363 State Number 24815 |
|--|

EQUIPMENT INSPECTED

| | | |
|----------------------------|----------------------------------|------------------------|
| State Number: 24815 | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 4000 | Manuf: ABELL | Speed: 75 |
| Landings: 2 | Installed: 01/05/2012 | Rope Size: |
| Volts: 480 | Complied: | Entrances: 1 |
| OWNER | OCCUPANT | |
| LANESBORO CORRECTIONAL | LANESBORO CORRECTIONAL INSTITUTE | |
| P O BOX 280 | 552 PRISON CAMP ROAD | |
| POLKTON, NC, 28135 | POLKTON, NC, 28135 | |

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|-----------------|---|
| Inspection Date 08/05/2014 | Type Inspection Routine | Certificate Status Re-issued | Inspector 8 - Burris | County ANSON | 4 |
|-------------------------------|----------------------------|---------------------------------|-------------------------|-----------------|---|

VIOLATIONS

8.6.4.15 RESTORE OPERATION OF ELEVATOR EMERGENCY PHONE. (WILL NOT RING TO SECURITY) (LEE BLDG)

Items must be corrected by: 09/04/2014

Elevator Name: LEE BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: BILL HART 704.695.1013

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LANESBORO CORRECTIONAL
P O BOX 280
POLKTON, NC, 28135