

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-807-2770

Report Number 14217-8-4363 State Number 24815
--

EQUIPMENT INSPECTED

State Number: 24815	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4000	Manuf: ABELL	Speed: 75
Landings: 2	Installed: 01/05/2012	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
LANESBORO CORRECTIONAL	LANESBORO CORRECTIONAL INSTITUTE	
P O BOX 280	552 PRISON CAMP ROAD	
POLKTON, NC, 28135	POLKTON, NC, 28135	

INSPECTION INFORMATION

Inspection Date 08/05/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County ANSON	4
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------	---

VIOLATIONS

8.6.4.15 RESTORE OPERATION OF ELEVATOR EMERGENCY PHONE. (WILL NOT RING TO SECURITY) (LEE BLDG)

Items must be corrected by: 09/04/2014

Elevator Name: LEE BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: BILL HART 704.695.1013

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LANESBORO CORRECTIONAL
P O BOX 280
POLKTON, NC, 28135