



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14219-59-3923**  
State Number  
**27268**

#### EQUIPMENT INSPECTED

State Number: <b>27268</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 11/24/2009	Rope Size:
Volts: 240	Complied:	Entrances: 2
OWNER	OCCUPANT	
18 CHURCH STREET LLC	ALTAMONT THEATER	
27 FOREST ROAD	18 CHURCH STREET	
ASHEVILLE, NC, 28803	ASHEVILLE, NC, 28801	

#### INSPECTION INFORMATION

Inspection Date 08/07/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 59 - Cannon	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

#### VIOLATIONS

- 8.6.10.1 Provide an updated monthly fire service log indicating proper Phase 1 and 2 operation and make available upon request the authority having jurisdiction.
- 8.6.1.4.1[a] Properly document maintenance records

Items must be corrected by: 09/06/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: [blee@myaltamont.com](mailto:blee@myaltamont.com)

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:  
18 CHURCH STREET LLC  
27 FOREST ROAD  
ASHEVILLE, NC, 28803