



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14225-48-4099**  
State Number  
**23724**

### EQUIPMENT INSPECTED

State Number: <b>23724</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 50
Landings: 4	Installed: 03/10/2006	Rope Size: 0
Volts: 230	Complied: 03/10/2006	Entrances: 1
OWNER OCEAN WALK HOA C/O GO PROPERTY MGMT-G OWEN WILMINGTON, NC, 28405		OCCUPANT OCEAN WALK CONDO #1 105 SE 58TH STREET OAK ISLAND, NC, 28465

### INSPECTION INFORMATION

Inspection Date 08/13/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

### VIOLATIONS

- 2.27.3.1 Put the Phase I fire service feature in proper working order. [NOT WORKING]
- 8.6.4.8.1 Clean the machine room (machinery space) of all debris.
- 8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).
- 8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 09/12/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN WALK HOA  
C/O GO PROPERTY MGMT-G OWEN  
WILMINGTON, NC, 28405