N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14226-16-4031
State Number
6865

EQUIPMENT INSPECTED

State Number: **6865**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 8000	Manuf: SOUTHERN	Speed: 50
Landings: 2	Installed: 07/28/1980	Rope Size: 0
Volts: 440	Complied: 06/14/1991	Entrances: 2

OWNER
CLARCOR ENGINE MOBILE SOLUTIONS CORP
PO BOX 1105
WASHINGTON, NC, 27889

OCCUPANT
CLARCOR ENGINE MOBILE SOLUTIONS CORP.
230 CLARKS NECK ROAD
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
08/14/2014	Routine	Re-issued	16 - Moore	BEAUFORT

7

VIOLATIONS

2.14.7.1.3 Put the in car emergency light in working order.

Items must be corrected by: 09/13/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Human Resources Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CLARCOR ENGINE MOBILE SOLUTIONS CORP
PO BOX 1105
WASHINGTON, NC, 27889