



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14226-36-3799
State Number
11235

EQUIPMENT INSPECTED

State Number: 11235	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 4000	Manuf: SOUTHERN	Speed: 150
Landings: 4	Installed: 05/20/1986	Rope Size:
Volts: 460	Complied: 06/24/1986	Entrances: 1

OWNER

ALAMANCE CO. JAIL
ELM STREET
GRAHAM, NC, 27253

OCCUPANT

ALAMANCE CO. JAIL
ELM STREET
GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date 08/14/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

- 8.6.10.1 Provide an updated monthly fire service log indicating proper Phase 1 and 2 operation and make available upon request the authority having jurisdiction.
- 8.11.2.3.1 Provide the annual no load test.

Items must be corrected by: 09/13/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Chris Rollins (336) 570-6700

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE CO. JAIL
ELM STREET
GRAHAM, NC, 27253