



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14226-36-5283
State Number
23195

EQUIPMENT INSPECTED

State Number: 23195	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 5000	Manuf: THYSSEN KRUPP	Speed: 110
Landings: 2	Installed: 09/26/2006	Rope Size: 0
Volts: 408	Complied: 09/26/2006	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE COUNTY	ALAMANCE COUNTY JAIL	
109 S MAPLE STREET	109 S MAPLE STREET	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 08/14/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

- 8.6.10.1 Provide an updated monthly fire service log indicating proper Phase 1 and 2 operation and make available upon request the authority having jurisdiction.
- 8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 09/13/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Chris Rollins (336) 570-6700

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE COUNTY
109 S MAPLE STREET
GRAHAM, NC, 27253