N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14226-48-2561
State Number
24258

EQUIPMENT INSPECTED

State Number: **24258**
Capacity: 2500
Landings: 4
Volts: 240

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 11/07/2006
Complied: 11/07/2006

Floor to Floor: 1 to 4
Speed: 50
Rope Size: 0
Entrances: 1

OWNER
OCEAN WALK HOA
C/O GO PROPERTY MGMT-G OWEN
WILMINGTON, NC, 28405

OCCUPANT
OCEANWALK CONDOS #5
105 SE 58TH STREET
OAK ISLAND, NC, 28465

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
08/14/2014	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.4.7.1	Clean the elevator pit.
2.2.5.1	Put the pit lights in proper working order.

Items must be corrected by: 09/13/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
OCEAN WALK HOA
C/O GO PROPERTY MGMT-G OWEN
WILMINGTON, NC, 28405