



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14226-52-2279
State Number
H1356

EQUIPMENT INSPECTED

State Number: H1356	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: NATL W-O-V	Speed: 9
Landings: 2	Installed: 03/31/2003	Rope Size: 0
Volts: 115	Complied: 03/31/2003	Entrances: 2
OWNER	OCCUPANT	
BANNER ELK METHODIST	BANNER ELK METHODIST	
PO BOX 1548	485 COLLEGE DRIVE SW	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 08/14/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Dan 828-260-4792

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK METHODIST
PO BOX 1548
BANNER ELK, NC, 28604