



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14226-52-3076
State Number
8962

EQUIPMENT INSPECTED

State Number: 8962	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 06/02/1977	Rope Size: 0
Volts: 220	Complied: 06/02/1977	Entrances: 1
OWNER	OCCUPANT	
ESEECOLA LODGE	ESEECOLA LODGE CLUBHOUSE	
P.O BOX 99	83 ROSEBORO ROAD	
LINVILLE, NC, 28646	LINVILLE, NC, 28646	

INSPECTION INFORMATION

Inspection Date 08/14/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

8.6.4.8.4	Take steps to keep the machine room access door locked at all times with the key on the premises.
8.6.4.7.4	Remove the oil and the oil soakers from the pit floor.
2.14.7.1.3	Put the in car emergency light in working order.
8.6	Monitor jack packing gland. Replace if needed.

Items must be corrected by: 09/13/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Hunter 828-733-4311

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ESEECOLA LODGE
P.O BOX 99
LINVILLE, NC, 28646