



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14226-52-4659
State Number
21513

EQUIPMENT INSPECTED

State Number: 21513	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 08/06/2003	Rope Size: 0
Volts: 208	Complied: 08/12/2003	Entrances: 1
OWNER	OCCUPANT	
BANNER ELK PRESBYTERIAN	BANNER ELK PRESBYTERIAN	
PO BOX 158	420 COLLEGE DRIVE	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 08/14/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

- 2.7.5.1 Put the machine room lights in working order.
- 8.6.1.6.5 Perform the annual inspection on the machine room fire extinguisher.
- 2.11.11.8 Install the missing door retainers where needed. (Bottom of doors at B and 1 levels. B floor needs 1 fire tab and 1st floor needs 2 fire tabs.)
- 8.11.3.2.1 Perform the annual relief valve and system pressure test and provide proper tag tpo controller. (Last date shown is June 2013)

Items must be corrected by: 09/13/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Banner Elk Presbyterian

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK PRESBYTERIAN
PO BOX 158
BANNER ELK, NC, 28604