



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14226-8-1641
State Number
16717

EQUIPMENT INSPECTED

State Number: 16717	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 150
Landings: 2	Installed: 02/14/1997	Rope Size:
Volts: 480	Complied: 02/19/1997	Entrances: 1
OWNER	OCCUPANT	
ANSON CO BOARD OF EDUCATION	ANSON CO HIGH SCHOOL	
320 CAMDEN RD	96 ANSON HIGH SCHOOL DR	
WADESBORO, NC, 28170	WADESBORO, NC, 28170	

INSPECTION INFORMATION

Inspection Date 08/14/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County ANSON
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

4

VIOLATIONS

8.6.4.13 REPLACE BROKEN 1ST FLOOR HALL CALL KEY SW

Items must be corrected by: 09/13/2014

Elevator Name: K-BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: GREG STURDIVANT 704.694.2725

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ANSON CO BOARD OF EDUCATION
320 CAMDEN RD
WADESBORO, NC, 28170