



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14230-48-0099**  
State Number  
**15582**

EQUIPMENT INSPECTED

State Number: <b>15582</b>	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 12000	Manuf: OTIS	Speed: 75
Landings: 2	Installed: 11/23/1994	Rope Size:
Volts: 480	Complied: 12/05/1994	Entrances: 1
OWNER	OCCUPANT	
SMITHFIELD PACKING	CAROLINA FOOD PROCESSORS	
1911 S. CHURCH ST.	NC HWY. 87S	
SMITHFIELD, VA, 23430	TARHEEL, NC, 28392	

INSPECTION INFORMATION

Inspection Date 08/18/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

3.24.1	Elevator pumping unit. [OIL IN BOTTOM OF PAN].
5.1.21.1	Put the in car alarm bell in working order.
2.14.7.1.4	Put the car top light in working order.
2.27.1.1.2	Put the in car emergency telephone in proper working order.
2.27.3.1	Put the Phase I fire service feature in proper working order. [KEY SWITCH]
8.6.4.8.1	Clean the machine room (machinery space) of all debris.
8.6.4.13.1[k]	Properly maintain door closers, where required. [MOTOR ROOM DOOR]
8.6.1.6.5	Provide a class ABC fire extinguisher in machinery space.
8.6.4.7.4	Remove the water from the pit floor.
8.11.3.2.1	Perform the annual relief valve test

Items must be corrected by: 09/17/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeff

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SMITHFIELD PACKING  
1911 S. CHURCH ST.  
SMITHFIELD, VA, 23430