



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14239-36-3148
State Number
25401

EQUIPMENT INSPECTED

State Number: 25401	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 3	Installed: 02/07/2007	Rope Size: 0
Volts: 208	Complied: 02/07/2007	Entrances: 1
OWNER	OCCUPANT	
ETHAN POINTE LLC	ETHAN POINTE APARTMENTS	
905 ARBORETUM DR	1176 KIRKPATRICK ROAD	
WILMINGTON, NC, 28403	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 08/27/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

2.7.3.4.1(b) Provide a self closing, self locking machine room door.

Items must be corrected by: 09/26/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: KAREN VEZINA 336-584-3337

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ETHAN POINTE LLC
905 ARBORETUM DR
WILMINGTON, NC, 28403