N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14266-48-4594
State Number
H1086

EQUIPMENT INSPECTED

State Number: **H1086**
Capacity: 750
Landings: 2
Volts: 120

Type of Unit: Hand Lift
Manuf: ACCEL
Installed: 09/19/2000
Complied: 09/19/2000

Floor to Floor: 1 to 2
Speed: 20
Rope Size:
Entrances: 2

OWNER
LOCKWOOD FOLLY COUNTRY CLUB
18 CLUBHOUSE DR, SW
SUPPLY, NC, 28462

OCCUPANT
LOCKWOOD FOLLY COUNTRY CLUB
18 CLUBHOUSE DR, SW
SUPPLY, NC, 28462

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
09/23/2014	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
2.27.1.1.2	Put the in car emergency telephone in proper working order.

Items must be corrected by: 10/23/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
LOCKWOOD FOLLY COUNTRY CLUB
18 CLUBHOUSE DR, SW
SUPPLY, NC, 28462