



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14266-48-5271
State Number
23829

EQUIPMENT INSPECTED

State Number: 23829	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 03/30/2006	Rope Size:
Volts: 208	Complied: 03/30/2006	Entrances: 1

OWNER

RIVERS EDGE GOLF CLUB
350 CHERRY HILL LANE
SHALLOTTE, NC, 28470

OCCUPANT

RIVERS EDGE CLUBHOUSE
350 CHERRY HILL LANE
SHALLOTTE, NC, 28470

INSPECTION INFORMATION

Inspection Date 09/23/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

N/A PUT COVERS BACK ON FIRE RECALL SWITCHES

Items must be corrected by: 10/23/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RIVERS EDGE GOLF CLUB
350 CHERRY HILL LANE
SHALLOTTE, NC, 28470