



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14280-59-4661
State Number
23181

EQUIPMENT INSPECTED

State Number: 23181	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 09/21/2005	Rope Size: 3/8"
Volts: 208	Complied: 09/23/2005	Entrances: 1
OWNER	OCCUPANT	
49 BROADWAY ARTS CONDOMINIUM ASSOC.	49 BROADWAY ARTS CONDOMINIUMS	
12 1/2 WALL STREET / SUITE "D"	49 BROADWAY AVE.	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 10/07/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 59 - Cannon	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

VIOLATIONS

5.1.21.1	Put the in car alarm bell in working order.
2.14.7.1.3	Put the in car emergency light in working order.
2.14.7.1	Put the car lights in proper working order.

Items must be corrected by: 10/17/2014

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: John Ball

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

49 BROADWAY ARTS CONDOMINIUM ASSOC.
12 1/2 WALL STREET / SUITE "D"
ASHEVILLE, NC, 28801