



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14294-48-2243
State Number
23515

EQUIPMENT INSPECTED

State Number: 23515	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 08/26/2006	Rope Size: 0
Volts: 208	Complied: 08/26/2006	Entrances: 1
OWNER	OCCUPANT	
EXUM FAMILY 503, LLC	WATERFORD PROFESSIONAL OFFICES	
P O BOX 1967	503 OLD WATERFORD WAY	
WILMINGTON, NC, 28402	LELAND, NC, 28451	

INSPECTION INFORMATION

Inspection Date 10/21/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: NICOLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

EXUM FAMILY 503, LLC
P O BOX 1967
WILMINGTON, NC, 28402