



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14294-48-4296
State Number
24755

EQUIPMENT INSPECTED

State Number: 24755	Type of Unit: Passenger	Floor to Floor: to
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 05/31/2007	Rope Size:
Volts: 208	Complied: 05/31/2007	Entrances: 1
OWNER	OCCUPANT	
EXUM FAMILY 497,LLC	WATERFORD TOWN HALL BLDG	
P O BOX 1967	497 OLD WATERFORD WAY	
WILMINGTON, NC, 28402	LELAND, NC, 28451	

INSPECTION INFORMATION

Inspection Date 10/21/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

N/A VALVE TEST TAG WIRING NOT PROPERLY THREADED.

Items must be corrected by: 11/20/2014

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: NICOLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

EXUM FAMILY 497,LLC
P O BOX 1967
WILMINGTON, NC, 28402