



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14294-52-5930
State Number
H2024

EQUIPMENT INSPECTED

State Number: H2024	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: NATL W-O-V	Speed: 9
Landings: 2	Installed: 09/29/2008	Rope Size: 0
Volts: 115	Complied:	Entrances: 2
OWNER	OCCUPANT	
LEE MCRAE COLLEGE	LEES MCRAE RECREATIONAL CENTER	
PO BOX 128	144 WILSON ROAD	
BANNER ELK, NC, 28604-0128	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 10/21/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

2.1.2.8 Replace missing platform grab bar end plug.

Items must be corrected by: 11/20/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lees Mcrae 828-898-8970

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LEE MCRAE COLLEGE
PO BOX 128
BANNER ELK, NC, 28604-0128