



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14295-8-4297**  
State Number  
**25740**

EQUIPMENT INSPECTED

State Number: <b>25740</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 5000	Manuf: TKE	Speed: 175
Landings: 2	Installed: 09/09/2008	Rope Size:
Volts: 480	Complied:	Entrances: 2
OWNER	OCCUPANT	
RANDOLPH HOSPITAL	RANDOLPH HOSPITAL	
364 WHITE OAK ST	364 WHITE OAK ST	
ASHEBORO, NC, 27204	ASHEBORO, NC, 27204	

INSPECTION INFORMATION

Inspection Date 10/22/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

2.29.1 LABLE ELEVATOR NUMBER ON C.O.P INSIDE CAR

Items must be corrected by: 11/21/2014

Elevator Name: #9 Cancer Ctr

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: SKIP RICHEY 336.625.8800

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RANDOLPH HOSPITAL  
364 WHITE OAK ST  
ASHEBORO, NC, 27204