



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14310-8-4679
State Number
8527

EQUIPMENT INSPECTED

State Number: 8527	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 3	Installed: 11/03/1976	Rope Size:
Volts: 480	Complied: 02/12/1993	Entrances: 1
OWNER	OCCUPANT	
CAMP CARAWAY	CAMP CARAWAY CONF CNTR	
PO BOX 36	4756 CARAWAY MT RD	
ASHEBORO, NC, 27203	SOPHIA, NC, 27350	

INSPECTION INFORMATION

Inspection Date 11/06/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

8.6.4.15 RESTORE ELEVATOR EMERGENCY LINGTING

Elevator Name: VISITOR/CONFERENCE CTR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: KATELYN HUFFMAN 336.629.2374

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAMP CARAWAY
PO BOX 36
ASHEBORO, NC, 27203