



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14311-8-0187
State Number
25634

EQUIPMENT INSPECTED

State Number: 25634	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 20000	Manuf: OTIS	Speed: 50
Landings: 2	Installed: 12/22/2008	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
MALT O MEAL	MALT O MEAL	
2525 BANK STREET	2525 BANK STREET	
ASHBORO, NC, 27203	ASHBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 11/07/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

8.6.4.15	RESTORE ELEVATOR EMERGENCY LIGHTING
8.6.11.1	REPLACE BURNED OUT BULBS IN PHASE II FIRE HAT FIXTUREINSIDE ELEVATOR
8.6.4.15.1	RESTORE FUNCTION OF ELEVATOR EMERGENCY PHONE

Items must be corrected by: 12/07/2014

Elevator Name: RTE BLDG LINE 1 & 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complinace with current codes.

Violations pointed out to: AL SPENCER

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
MALT O MEAL
2525 BANK STREET
ASHBORO, NC, 27203