



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14316-46-0126
State Number
5938

EQUIPMENT INSPECTED

State Number: **5938** Type of Unit: Passenger Floor to Floor: 1 to 6
Capacity: 2000 Manuf: SCHINDLER Speed: 300
Landings: 6 Installed: 03/27/1968 Rope Size: 1/2
Volts: 208 Complied: 04/08/1968 Entrances: 1

OWNER
COLLIERS INTERNATIONAL
PO BOX 10810
RALEIGH, NC, 27605

OCCUPANT
FIRST RALEIGH TELEX
234 FAYETTEVILLE ST
RALEIGH, NC, 27601

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
11/12/2014	Routine	Re-issued	46 - Jones	WAKE	92 D

VIOLATIONS

- 8.11.2.2.2 Perform an annual no load safety test and provide proper tags. (test was due 11-13) (5 day notice)
- 8.6.5.5.1 Where elevator machines use packing glands or seals, they shall be maintained to prevent excessive loss of fluid. (seal machine oil leaks) (2nd notice)
- 8.6.4.13.1 Clean lubricate & adjust door operator chain. (rust) (slack) (2nd notice)
- 8.6.4.8.1 Clean the elevator machine room.
- NEC 620 Secure audible device on T.O.C. inspection station

Items must be corrected by: 11/22/2014

Elevator Name: ELEVATOR #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Julie Wood

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COLLIERS INTERNATIONAL
PO BOX 10810
RALEIGH, NC, 27605