



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14316-7-5873
State Number
19072

EQUIPMENT INSPECTED

State Number: 19072	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 2	Installed: 12/19/2000	Rope Size:
Volts: 208	Complied: 12/19/2000	Entrances: 1
OWNER	OCCUPANT	
BALD MOUNTAIN BAPTIST CH	BALD MOUNTAIN BAPTIST CH	
1460 BALD MTN RD	1460 BALD MTN RD	
W JEFFERSON, NC, 28640	W JEFFERSON, NC, 28640	

INSPECTION INFORMATION

Inspection Date 11/12/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ASHE
-------------------------------	----------------------------	---------------------------------	--------------------------	----------------

5

VIOLATIONS

NONE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: BALD MTN.BAPTIST 336-877-1550

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BALD MOUNTAIN BAPTIST CH
1460 BALD MTN RD
W JEFFERSON, NC, 28640